

Amica Chips WWTP

- Industrial/ Water Reuse Installation for Amica Chips WWTP in Castiglione delle Stiviere, Northern Italy
- Design Fluxes
 Average Day Flux = 11.0 LMH/ 6.5 GFD
- FPC400 Cassette (384 modules in 2 trains)
- Operating since May 2018

Parameter	Influent	Desired Effluent	Effluent
COD	1200		
BOD	600		
TSS	150		
TKN	60		